

Checklist for Inspecting Walking/Working Surfaces

General Work Environment

	Y	N
Is a documented, functioning housekeeping program in place?	<input type="checkbox"/>	<input type="checkbox"/>
Are all work sites clean, sanitary and orderly?	<input type="checkbox"/>	<input type="checkbox"/>
Are work surfaces kept dry or have appropriate means been taken to assure the surfaces are slip-resistant?	<input type="checkbox"/>	<input type="checkbox"/>
Are all spilled hazardous materials or liquids, including blood and other potentially infectious materials, cleaned up immediately and according to proper procedures?	<input type="checkbox"/>	<input type="checkbox"/>
Is combustible scrap, debris and waste stored safely and removed from the work site properly?	<input type="checkbox"/>	<input type="checkbox"/>
Is all regulated waste, as defined in the Cal/OSHA Standards (CCR Title 8), discarded according to federal, state and local regulations?	<input type="checkbox"/>	<input type="checkbox"/>
Are accumulations of combustible dust routinely removed from elevated surfaces including the overhead structure of buildings, etc.?	<input type="checkbox"/>	<input type="checkbox"/>
Is combustible dust cleaned up with a vacuum system to prevent the dust from going into suspension?	<input type="checkbox"/>	<input type="checkbox"/>
Is metallic or conductive dust prevented from entering or accumulating on or around electrical enclosures or equipment?	<input type="checkbox"/>	<input type="checkbox"/>
Are covered metal waste cans used for oily and paint-soaked waste?	<input type="checkbox"/>	<input type="checkbox"/>

Walkways

	Y	N
Are aisles and passageways kept clear?	<input type="checkbox"/>	<input type="checkbox"/>
Are aisles and walkways marked as appropriate?	<input type="checkbox"/>	<input type="checkbox"/>
Are wet surfaces covered with non-slip materials?	<input type="checkbox"/>	<input type="checkbox"/>
Are holes in the floor, sidewalk or other walking surfaces repaired properly, covered or otherwise made safe?	<input type="checkbox"/>	<input type="checkbox"/>
Is there safe clearance for walking in aisles where motorized or mechanical handling equipment is operating?	<input type="checkbox"/>	<input type="checkbox"/>
Are materials or equipment stored in such a way that sharp objects will not interfere with the walkway?	<input type="checkbox"/>	<input type="checkbox"/>
Are spilled materials cleaned up immediately?	<input type="checkbox"/>	<input type="checkbox"/>
Are changes of direction or elevation readily identifiable?	<input type="checkbox"/>	<input type="checkbox"/>
Are aisles or walkways that pass near moving or operating machinery, welding operations or similar operations arranged so employees will not be subjected to potential hazards?	<input type="checkbox"/>	<input type="checkbox"/>
Is adequate headroom provided for the entire length of any aisle or walkway?	<input type="checkbox"/>	<input type="checkbox"/>
Are standard guardrails provided wherever aisle or walkway surfaces are elevated more than 30in. above any adjacent floor or the ground?	<input type="checkbox"/>	<input type="checkbox"/>
Are bridges provided over conveyors and similar hazards?	<input type="checkbox"/>	<input type="checkbox"/>

Floor and Wall Openings

	Y	N
Are floor openings guarded by a secure cover, a guardrail, or equivalent on all sides (except at entrance to stairways or ladders)?	<input type="checkbox"/>	<input type="checkbox"/>
Are toe boards installed around the edges of permanent floor openings (where persons may pass below the opening)?	<input type="checkbox"/>	<input type="checkbox"/>
Are skylight screens of such construction and mounting that they will withstand a load of at least 200 pounds?	<input type="checkbox"/>	<input type="checkbox"/>
Is the glass in the windows, doors, glass walls, etc., which are subject to human impact, of sufficient thickness and type for the condition of use?	<input type="checkbox"/>	<input type="checkbox"/>

Checklist for Inspecting Walking/Working Surfaces

Floor and Wall Openings (cont'd)

- | | Y | N |
|--|--------------------------|--------------------------|
| Are grates or similar type of covers over floor openings such as floor drains of such design that foot traffic or rolling equipment will not be affected by the grate spacing? | <input type="checkbox"/> | <input type="checkbox"/> |
| Are unused portions of service pits and pits not actually in use, either covered or protected by guardrails or equivalent? | <input type="checkbox"/> | <input type="checkbox"/> |
| Are manhole covers, trench covers and similar covers, plus their supports, designed to carry a truck rear axle load of at least 20,000 pounds when located in roadways and subject to vehicle traffic? | <input type="checkbox"/> | <input type="checkbox"/> |
| Are floor or wall openings in fire resistive construction provided with doors or covers compatible with the fire rating of the structure and provided with a self-closing feature when appropriate? | <input type="checkbox"/> | <input type="checkbox"/> |

Stairs and Stairways

- | | Y | N |
|--|--------------------------|--------------------------|
| Are standard stair rails or handrails on all stairways having four or more risers? | <input type="checkbox"/> | <input type="checkbox"/> |
| Are all stairways at least 22 inches wide? | <input type="checkbox"/> | <input type="checkbox"/> |
| Do stairs have landing platforms not less than 30 inches in the direction of travel and extend 22 inches in width at every 12 feet or less vertical rise? | <input type="checkbox"/> | <input type="checkbox"/> |
| Do stairs angle no more than 50 degrees and no less than 30 degrees? | <input type="checkbox"/> | <input type="checkbox"/> |
| Are step risers on stairs uniform from top to bottom? | <input type="checkbox"/> | <input type="checkbox"/> |
| Are steps on stairs and stairways designed or provided with a surface that renders them slip resistant? | <input type="checkbox"/> | <input type="checkbox"/> |
| Are stairway handrails located between 30 and 34 inches above the leading edge of the stair treads? | <input type="checkbox"/> | <input type="checkbox"/> |
| Do stairway handrails have at least three (3) inches of clearance between the handrails and the wall or surface they are mounted on? | <input type="checkbox"/> | <input type="checkbox"/> |
| Where doors or gates open directly on a stairway, is there a platform provided so the swing of the door does not reduce the width of the platform to less than 21 inches? | <input type="checkbox"/> | <input type="checkbox"/> |
| Where stairs or stairways exit directly into any area where vehicles may be operated, are adequate barriers and warnings provided to prevent employees from stepping into the path of traffic? | <input type="checkbox"/> | <input type="checkbox"/> |
| Do stairway landings have a dimension measured in the direction of travel, at least equal to the width of the stairway? | <input type="checkbox"/> | <input type="checkbox"/> |

Elevated Surfaces

- | | Y | N |
|--|--------------------------|--------------------------|
| Are signs posted, when appropriate, showing the elevated surface load capacity? | <input type="checkbox"/> | <input type="checkbox"/> |
| Are surfaces elevated more than 30 inches above the floor or ground provided with standard guardrails? | <input type="checkbox"/> | <input type="checkbox"/> |
| Are all elevated surfaces (beneath which people or machinery could be exposed to falling objects) provided with standard four (4) inch toe boards? | <input type="checkbox"/> | <input type="checkbox"/> |
| Is a permanent means of access and egress provided to elevated storage and work surfaces? | <input type="checkbox"/> | <input type="checkbox"/> |
| Is required headroom provided where necessary? | <input type="checkbox"/> | <input type="checkbox"/> |
| Is material on elevated surfaces piled, stacked or racked in a manner to prevent it from tipping, falling, collapsing, rolling or spreading? | <input type="checkbox"/> | <input type="checkbox"/> |
| Are dock boards or bridge plates used when transferring materials between docks and trucks or rail cars? | <input type="checkbox"/> | <input type="checkbox"/> |